



Government Of West Bengal
Office Of The Divisional Fire Officer, Purba Bardhaman
West Bengal Fire & Emergency Services
Bhangakhuti, Purba Burdwan, P.O.:- Rajbati, Pin :- 713104

Memo no.: FSR/0125186210300083

Date: 25-04-2021

From:

Divisional Fire Officer, Purba Bardhaman
West Bengal Fire & Emergency Services

To: Shemford Futuristic School, Katwa.

Tikarkhanji, Sudpur, Mouza Tikarkhanji, Pataihat, Plot no. 180, 181, 206, 206/1574, 207, 779, 785, 788 to 792, Kh. no. 2746, 2747, 956, 957, J.L no. 82, 88, P.S Katwa, Purba Bardhaman, 713140.

Sub: Fire Safety Certificate for occupancy of an existing construction of G+III storied educational building under name and style as Shemford Futuristic School, Katwa. Over plot Vill Tikarkhanji, P.O Sudpur, Plot no. 180, 181, 206, 206/1574, 207, Mouza Tikarkhanji, Plot no. 779, 785, 788 to 792, Mouza Pataihat, Kh. no. 2746, 2747, 956, 957, J.L no. 82, 88, Under Sudpur G.P, P.S Katwa, Dist. Purba Bardhaman, Pin 713140. for issuance of Fire Safety Certificate against online application no :- 0125189210300058

This is in reference to your application no. 0125189210300058 dated 21-04-2021 regarding the Fire Safety Certificate for occupancy of an existing construction of G+III storied educational building under name and style as Shemford Futuristic School, Katwa. Over plot Vill Tikarkhanji, P.O Sudpur, Plot no. 180, 181, 206, 206/1574, 207, Mouza Tikarkhanji, Plot no. 779, 785, 788 to 792, Mouza Pataihat, Kh. no. 2746, 2747, 956, 957, J.L no. 82, 88, Under Sudpur G.P, P.S Katwa, Dist. Purba Bardhaman, Pin 713140. for issuance of Fire Safety Certificate against online application no :- 0125189210300058

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Fire Safety Certificate for occupancy of the aforesaid building.

Recommendation:

1. Maintenance/checking /testing of all fire safety installations shall be checked time to time.
2. Any nominated officer of this Deptt. Shall enter and inspect the building at any time between sunrise to sunset for ascertaining the contravention if any of Fire prevention and fire safety measures.
3. Good house keeping should be always to be maintained.
4. Mock Drill must be performed twice in a year and recorded properly.
5. To up-keep the Fire Safety Measures of the aforesaid building the following safety measures are to be incorporated.
6. Driveway must be free of any type of obstruction for easy movement of Fire Appliances.

No parking will be allowed on the Driveway.

8. The interior finish decoration of the building shall be made with low flame spread material confirming to the I.S. Specification.
 9. To eliminate risk of fire hazards, good house-keeping both for inside and outside of the building shall be strictly maintained.
 10. Existing Electrical wiring of the whole building shall have to be carefully checked for any wear and tear in them, particularly lines above false ceiling and ducts.
 11. The notice of Fire Fighting and Evacuation from the building shall be prepared and displayed at all vulnerable of the building.
 12. The employees and security staffs shall be conversant with installed Fire Fighting Equipments of the building and to operate in the event of Fire and Testing.
 13. Mock Fire practice and Evacuation Drill shall be performed periodically with participants of all the occupants of the building.
 14. A crew of trained Fire Man under an experience officer shall be maintained round the clock for safety of the building.
 15. First-Aid Fire Fighting system shall be provided as per I.S. specification.
 16. Arrangement shall have to be made for regular checking, testing and maintenance of all the fire fighting installation in the building to keep them in perfectly good working condition at all the times.
 17. If required the old lines shall have to be replaced with new lines, the cable shall always be laid in M.S. conduit pipes continuously bonded with the earth.
 18. Electrical ducts shall be sealed vertically and horizontally at each floor level by fire resisting materials.
 19. 1 no. stand by pump 900 lpm shall be provided with in 30 days
 20. The Fire Safety Audit to be conducted a regular interval and to be recorded in the fire prevention maintenance register.
 21. Violation of any recommendations which issued from this office previously this fire safety certificate shall be treated as cancelled.
- This certificate shall remain valid up to Three years as per existing Govt. Rule.

Signature valid

Signed by: NITAI CHANDRA TOPADHYAY
Reason: Approved
Location: West Bengal
Date: 25-Apr-2021 21:13:53

Divisional Fire Officer, Purba Bardhaman
West Bengal Fire & Emergency Services

Application Acknowledgement



West Bengal
eDISTRICT 2.0

Single Window Portal - Citizen Centric Services & Schemes

Dear Mr. Bimalendu Kundu ,

Thank you for using West Bengal e-District 2.0 System.

Your application for Renewal of Fire Safety Certificate under Government of West Bengal has been successfully submitted.

Application Summary

AIN : 2119124063000000041

Name of the Applicant : Mr. Bimalendu Kundu

Date of the Application : 21-Mar-2024

Address : Under Sudpur G.P , J.L no. 82, 88 ,Village/ Ward:- Tikarkhanji
, Post Office:- Sudpur , Police Station:- Katwa PS , Purba
Bardhaman , West Bengal , India , Pincode :- 713140.

For any query please contact your nearest Kiosk operator or the following contact details:

Government Of West Bengal Office Of The Divisional Fire Officer ,Paschim Bardhaman West Bengal Fire & Emergency Services Bhangakhuti, Purba Burdwan, P.O.:- Rajbati, Pin :- 713104

Applicants have to submit physical documents in proper order at the intimated Offices of Divisional Fire Officer within 04(four) days,failing which systematically/automatically applications will be rejected.



Existing FSR Details for which Renewal of FSC is needed

Existing FSR No.*
0125186210300083

Application Details

Applicant Type	Salutation	First Name	Middle Name
Others	Mr.	Bimalendu Kundu	NA
Last Name	Date Of Birth	Age	Gender
NA	4-AUGUST-1986	34	Male
Date of Application	Mobile Number	Email	Aadhaar
21-MARCH-2024	6294672721	bimalendu.kundu@gmail.com	*****5716
PAN Number			
AMKPK7669A			

Previous Application Details, If any

Previous Application Id	Name of the Applicant in the Previous Application	Reason for Rejection
-------------------------	---	----------------------

Name and Address Shown on Recommendation

Name to be Printed on the Recommendation*
Shemford Futuristic School, Katwa.

Address to be printed on Recommendation*
Vill Tikarkhanji, P.O Sudpur, Plot no. 180, 181, 206, 206/1574, 207, Mouza Tikarkhanji, Plot no. 779, 785, 788 to 792, Mouza Pataihat, Kh. no. 2746, 2747, 956, 957, J.L no. 82, 88, Under Sudpur G.P, P.S Katwa, Dist. Purba Bardhaman, Pin 713140.

Revised Name and or Address to be shown on Recommendation

Name to be Printed on the Recommendation
Shemford Futuristic School

Address to be printed on Recommendation
Tikarkhanji, P.O-Sudpur, Mouza
Tikarkhanji, BLOCK-Katwa-1, P.S Katwa, Dist. Purba Bardhaman, Pin 713140.

Name to be Printed on the Recommendation
NA

Address of the Property

Country	State	District	Sub Division
India	West Bengal	Purba Bardhaman	Katwa
Rural/Urban	Block/Municipality	Block/Municipality Name	Village Ward
R	B	Katwa-II	Tikarkhanji
Police Station	Post Office	Address Line 1	Address Line 2
Katwa PS	Sudpur	Under Sudpur G.P	J.L no. 82, 88
Pincode	Nearest Fire Station to the Premises	Zone	Plot No./Holding No./Premises No.
713140	Katwa	2	779 - 792