



Government of West Bengal
Office of the Divisional Fire Officer
West Bengal Fire & Emergency Services
Bhangakhuti, Purba Burdwan, P.O.:- Rajbati, Pin :- 713104

Memo No.: FSR/0125186210300083

Date : 12-07-2024

From :
Divisional Fire Officer
Purba Bardhaman Division,
West Bengal Fire & Emergency Services

To :
Shemford Futuristic School, Katwa.
Vill Tikarkhanji, P.O Sudpur, Plot no. 180, 181, 206, 206/1574, 207, Mouza Tikarkhanji, Plot no. 779, 785, 788 to 792, Mouza Pataihat, Kh. no. 2746, 2747, 956, 957, J.L no. 82, 88, Under Sudpur G.P, P.S Katwa, Dist. Purba Bardhaman, Pin 713140.

Sub : Renewal of Fire Safety certificate for the occupancy of an Existing Construction of G+111 Storied under group o EDUCATIONA Building name in the style" Shemford Futuristic School", Katwa. in favour of Bimalendu Kundu Vill Tikarkhanji, P.O Sudpur, Plot no. 180, 181, 206, 206/1574, 207, Mouza Tikarkhanji, Plot no. 779, 785, 788 to 792, Mouza Pataihat, Kh. no. 2746, 2747, 956, 957, J.L no. 82, 88, Under Sudpur G.P, P.S Katwa, Dist. Purba Bardhaman, Pin 713140.

This is in reference to your AIN 211912406300001205 dated 02-Jul-2024 regarding Renewal of Fire Safety certificate for the occupancy of an Existing Construction of G+111 Storied under group o EDUCATIONA Building name in the style" Shemford Futuristic School", Katwa. in favour of Bimalendu Kundu Vill Tikarkhanji, P.O Sudpur, Plot no. 180, 181, 206, 206/1574, 207, Mouza Tikarkhanji, Plot no. 779, 785, 788 to 792, Mouza Pataihat, Kh. no. 2746, 2747, 956, 957, J.L no. 82, 88, Under Sudpur G.P, P.S Katwa, Dist. Purba Bardhaman, Pin 713140.

The performance of the Fire Fighting System as incorporated in the building were tested at random and found satisfactorily working condition. In view of the above this office is releasing the **Renewal of Fire Safety Certificate** for occupancy of the aforesaid building.




Principal
Shemford Futuristic School, Katwa


Manager
Shemford Futuristic School Katwa

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated maintained.

Recommendation:

1. Driveway must be free of any type of obstruction for easy movement of fire appliances, No parking will be allowed on the drive way.
 2. The interior finish decoration of the building shall be made low flame spread materials: conforming I.S. specifications.
 3. To eliminate risk of fire hazard, good housekeeping both for inside and outside of the building shall be strictly maintained.
 4. Existing electrical wiring of the whole building shall have to be carefully checked for any were and tear in them, particularly lines above false ceiling and ducts.
 5. The employees and security staff shall be conversant with installed Fire Fighting equipment's of the building and to operate in the event of Fire and Testing.
 6. Mock Fire practice and evacuation drill shall be performed periodically with participation of all occupants of building.
 7. Transformer and switch gear room shall be protected with automatic co2 or DCP fire. extinguisher conforming I.S specification.
 8. First aid fire fighting system shall be provided as per I.S specification.
 9. Arrangement shall be made for regular checking, testing and proper maintenance of all the Fire Safety installation and equipment's installed in the building to keep them in perfectly good working conditions at all times.
 10. Fire License shall have to be obtained for storing and processing with highly combustible articles.
 11. The Renewal of Fire Safety Certificate is valid for a period of three years from the date of issue, and has to be renewed after three years certifying about the satisfactory services, performance of all the Life and Fire Safety arrangements installation of the building.
- N.B. :Any deviation and changes the nature of use of the building in respect to approved plan drawing , without obtaining prior permission from this office, this Renewal of Fire Safety Certificate will be treated as canceled.

Valid Upto : 11-Jul-2027

FSR/0125186210300083



Principal
Shemford Futuristic School, Katwa

Manager
Shemford Futuristic School Katwa

Signature valid

Digitally Signed.
Name: SHUJAN KUMAR MAZUMDER
Date: 12-Jul-2024 10:30:27
Reason: D-Sign
Location: E-Dist 20

Divisional Fire Officer

West Bengal Fire & Emergency Services

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211912406300001205